

AT MICROFICHE
REFERENCE
LIBRARY
A project of Volunteers in Asia

Hydraulic Rams

By: J.H.P.M. Tacke and C. Verspuy

Published by: CICAT/ Faculty of Civil Engineering
TU Delft
Delft University of Technology
The Netherlands

Available from: CICAT/ Faculty of Civil Engineering
TU Delft
Delft University of Technology
The Netherlands


Reproduced with permission.


Reproduction of this microfiche document in any form is subject to the same restrictions as those of the original document.

Hydraulic Rams

August 1989

J.H.P.M. Tacke and C. Verspuy




TU Delft

CICAT / Faculty of Civil Engineering

Delft University of Technology

HYDRAULIC RAMS

In 1987 Peter de Jong of CICAT (the coordinating centre of the development cooperation effort of Delft University of Technology) published: "Hydraulic Rams, a consumers' guide".

This guide summarized the results of research on hydraulic rams, commissioned by the Section of Research and Technology of the Netherlands Ministry of Foreign Affairs.

The research comprised comparative tests of commercially available and newly designed hydraulic rams, and was carried out by the Delft University of Technology and in the field in Rwanda.

The laboratory research has been reported upon in 'World Pumps' (July 1989) by ir. J.H.P.M. Tacke and ir. C. Verspuy. This booklet is based on that article.

Dr. A. Wouters
Coordinator CICAT




Fig. 1 Typical hydraulic ram installation

HYDRAULIC RAMS

Introduction

The hydraulic ram is an automatic water pumping device that utilizes the energy contained in a flow of water running through it, to lift a small volume of this water to a higher level. The phenomenon involved is that of a pressure surge which develops when a moving mass of water is suddenly stopped (waterhammer.)

Hydraulic rams can be used for pumping drinking water from a spring or stream to a tank or reservoir at a higher level. A steady and reliable supply of water is required with a fall sufficient to operate the ram. Favourable conditions are mostly found in hilly and mountainous areas with fairly plentiful supplies of water. A well-made ram will pump an appropriate amount of water to a height from about 20 to 30 times the supply head, with an efficiency of about 60 to 70 per cent. Alternatively, hydraulic rams can be used for pumping water to low heads over large distances (up to 10 km or more), i.e. vertical lift can be traded off for horizontal distance.

In the past quite a number of hydraulic rams have been installed and many have given long and reliable service. But in modern times the availability of piped water systems using engine-driven pumps has relegated the hydraulic ram to a comparatively unimportant position. Recently, though, it has revived as a potentially useful component in rural water supply programs in developing countries. Yet, up to now the use of the hydraulic

ram in developing countries has not become as widespread as its simplicity, ease of operation and maintenance, dependability and economy would seem to warrant. This has largely been due to the lack of reliable information concerning the limiting conditions under which the ram is applicable and the phenomena governing its action.

In this article the essential features of hydraulic ram operation are described, using a limited number of experimental results. These results are part of the results obtained from a comparative investigation on commercially-available hydraulic rams, carried out at the Delft University of Technology (lit. [4]).

Mode of operation

Fig. 1 shows the various components from which a typical hydraulic ram installation is constructed: supply reservoir - drive pipe - hydraulic ram - delivery pipe - storage tank. The hydraulic ram itself is structurally simple, consisting of a pump chamber fitted with only two moving parts: an impulse valve through which the driving water is wasted (waste valve) and a check valve through which the pumped water is delivered (delivery valve). Surmounting the delivery valve is the air chamber or surge tank. When the ram operates this tank is partly filled with water and partly with air. Connected to the air chamber is the delivery pipe, so that the pressure in the air chamber is the delivery pressure. An inclined conduit, the so-called drive pipe, connects the ram




Fig. 2 Operation of the hydraulic ram




Fig. 3 Velocity $u(t)$ at the downstream end of the drive pipe

body with the water supply. This drive pipe is the essential part of the installation in which the potential energy of the supply water is first converted into kinetic energy and subsequently into the potential energy of water delivered.

The ram operates on a flow of water accelerating under a head H_1 from the supply reservoir down through the drive pipe into the pump chamber. The water escapes through the opened waste valve into the surrounding area (Fig. 2a). With the acceleration of the water in the drive pipe the hydrodynamic drag and pressure on the waste valve will increase. When the flow of water through the waste valve attains sufficient velocity, the upward force on the valve will exceed its weight and the valve will slam shut. (In a good ram design the valve closure is rapid, almost instantaneous.)

Thus the flow through the waste valve is abruptly stopped, but since the column of water in the drive pipe still has a considerable velocity a high pressure develops in the ram, locally retarding the flow of water. If the pressure rise is large enough to overcome the pressure in the air chamber the delivery valve will be forced open (Fig. 2b), which in turn limits the pressure rise in the ram body to slightly above the delivery pressure. The front of this pressure rise travels upstream, partly reducing the flow velocity in successive cross-sections of the drive pipe as it passes. In the meantime the remainder of the flow passes through the opened delivery valve into the air chamber. The air cushion permits water to be stored temporarily in the air chamber with only a comparatively low rise in local pressure, thus preventing the occurrence of waterhammer (shock waves) in the delivery pipe. With the propagation of successive pres-

sure surges up and down the drive pipe, water continues to flow into the air chamber with step-wise decreasing velocity until the momentum of the water column in the drive pipe is exhausted. The higher pressure which now exists in the air chamber causes the delivery valve to close, thus preventing the pumped water from flowing back into the ram body, while the water in the drive pipe is flowing away from the ram in the direction of the supply reservoir (Fig. 2c). The 'recoil' of water in the drive pipe produces a slight suction in the ram body, thus creating an underpressure near the waste valve. The underpressure allows the waste valve to reopen, water starts to flow out again, and a new operating cycle begins (Fig. 2d). Meanwhile the water forced into the air chamber, is driven at a constant rate into the delivery pipe to the storage tank at the high level, from which it can be distributed by gravitation as required.

An air valve or snifting-valve is mounted into the ram body to allow a small amount of air to be sucked in during the suction part of the ram cycle. This air is carried along with the next surge of water into the air chamber. The air in this chamber is always compressed and needs to be constantly replaced as it becomes mixed with the water and lost to the storage tank. Without a suitable air valve the air chamber would soon be full of water; the hydraulic ram would then cease to function.

A schematized diagram of the velocity at the downstream end of the drive pipe as a function of time is presented in Fig. 3. The figure clearly pictures the three sub-periods that can be distinguished in a complete cycle of operation:

T_1 = period of acceleration (wasting);
waste valve open, delivery valve








Fig. 4 Pressure + time recordings

closed; positive velocity (towards the ram).

T_4 = period of retardation (pumping); waste valve closed, delivery valve open; decelerating flow into the air chamber.

T_1 = period of recoil (reverse flow); delivery valve closed, waste valve reopens; negative flow (towards the supply reservoir).

During T_2 and T_1 the velocity $u(t)$, theoretically described by a hyperbolic tangent function, is almost linear; during T_4 the velocity $u(t)$ decreases step-wise in proportion to the delivery head h_d .

Depending on supply head (H_s), drive pipe length (L_d), waste valve adjustment and to a lesser degree on delivery head (h_d) the cycle is repeated with a frequency of about 30 to 150 times a minute (period $T = 0.40 - 2.00$ s). Once the adjustment of the waste valve has been set, the hydraulic ram needs almost no attention provided the water flow from the supply source is continuous and at an adequate rate and no foreign matters get into the pump blocking the valves.

Physical description

As became clear in the previous section, the action of both waste valve and delivery valve is of paramount importance for a successful operation of the hydraulic ram. A good impression of valve action can be obtained by observing the pressure variations both at the downstream end of the drive pipe, i.e. near to the ram (point A in Fig. 4a) and in the air chamber of the ram itself (point B). As an example Fig. 4b illustrates pressure + time diagrams recorded simultaneously at point A and B of a specific ram installation

operating under a supply head $H_s = 3.00$ m and a delivery head $h_d = 35$ m. The recording length amply covers three complete periods of the continuous 'heart-beat' of the hydraulic ram. The pressure variations observed during the period of retardation, are shown in detail in Fig. 4c. It should be noted that the diagrams portray the pressure variations as measured relative to the local quasi-static pressure; besides, for convenience all pressures were converted to pressure heads ($h = p/\rho g$) before being plotted.

It can be seen from the figures that, indeed, after a relative long period of acceleration a sudden pressure rise is created in the ram body (moment of waste valve closure). Within a few milliseconds this pressure rise drops to a value approximately equal to the delivery pressure ($h = h_d$), thus indicating that the delivery valve has opened. This may also be observed from the pressure + time recording for the air chamber, in which both opening and closing of the delivery valve are distinctly marked by sudden pressure fluctuations, the first because of the sudden flow of water into the air chamber, the latter due to the rebound of the water tending to flow back out of the air chamber. The propagation of successive pressure waves, moving at an acoustic wavespeed (c) up and down the drive pipe during the period of retardation, may be apparent from the pressure recording at point A. (Note: for water in a steel pipe the wavespeed $c = 1400$ m/s.) With the propagation of successive pressure surges (each surge requiring $2L_d/c$ second to move up and down the drive pipe) the velocity of the water in the drive pipe decreases step-wise in proportion to the magnitude of the pressure surge ($h = h_d$): $\Delta u = 1/4 h_d$; see Fig. 3. Therefore, for a given waste valve setting (i.e. for known




Fig. 5 Performance characteristics,
 2 1/2"-hydraulic ram
 $H_s = 2$ m; $Q = 100$ l/min; $T = 1$ s.




Fig. 6 Effect of supply head on ram perform-
 ance, 2 1/2"-hydraulic ram

velocity u_c of the water in the drive pipe at waste valve closure), the number of surges (N) observed during the period of retardation is determined by the delivery head h_d (when h_d decreases, Δu decreases and N increases). In this case ($h_d = 35$ m) it was found that $N = 3$, see Fig. 4c, resulting in the velocity steps as already shown in Fig. 3.

From Fig. 3 two volumes of water can be established, V_w and V_d , by integration of $u(t)$ with respect to time and multiplication by the cross-sectional area of the drive pipe:

$$V_w = \frac{\pi D^2}{4} \left[\int_0^{T_1} u(t) dt + \int_{T_1+T_d}^T u(t) dt \right]$$

$$V_d = \frac{\pi D^2}{4} \int_{T_1}^{T_1+T_d} u(t) dt$$

Finally, from these expressions the waste flow Q can be obtained from:

$$Q = \frac{V_w}{T}$$

and the pumping rate q from:

$$q = \frac{V_d}{T}$$

Performance characteristics

For the end-users of the hydraulic ram installation the pumping rate q is the first consideration, since this amount should meet their demand. Given an available source supply the pumping rate q of a hydraulic ram is primarily determined by the supply head H_s and the delivery head h_d . As an example Fig. 5 shows perform-

ance characteristics compiled from measurements taken on a commercially-made 2 1/2"-hydraulic ram operating under a supply head $H_s = 2.00$ m. It can be seen from the figure that the hydraulic ram can pump much water for low delivery heads, but as the delivery head increases the pumping rate decreases as might be expected. Fig. 5 also pictures efficiency versus delivery head; the efficiency curve shows that this specific ram can pump water with an efficiency of about 60 % over a broad range of delivery heads.

An increase of supply head H_s increases the pumping frequency (more beats per minute) and by that the pumping rate q increases. This may be noted from Fig. 6 showing q, h_d -curves resulting from experiments carried out on the same 2 1/2"-hydraulic ram, for $H_s = 1.35$ m, 2.00 m and 3.00 m respectively.

Commercially-made hydraulic rams are available in various sizes, covering a wide range of source supplies. The size of the ram (traditionally given in inches) usually denotes the nominal diameter (D) of the drive pipe. The larger the size of the ram the more water is required to operate the ram and the more water can be delivered to a higher level. For example, Fig. 7 compares ram performances for various arrangements of supply and delivery heads for two rams of the same manufacture but of different size: an 1 1/2"-ram and a 2 1/2"-ram respectively. It may also be observed from the figure that a small amount of water with 'plenty' of fall (e.g. $Q = 40$ l/min; $H_s = 3$ m) will deliver as much water as an arrangement using plenty of water having only a small fall ($Q = 100$ l/min; $H_s = 1.50$ m).

Finally, eliminating the effects of supply




Fig. 7 Effect of ram size on ram performance,
 $2\frac{1}{2}$ "-ram: $Q \approx 100$ l/min,
 $1\frac{1}{2}$ "-ram: $Q \approx 40$ l/min.




Fig. 8 Flow ratio versus head ratio

head (H_s) and ram size (D) leads to a dimensionless curve depicting flow ratio (q/Q) versus head ratio (h_d/H_s); see Fig. 8. The objective of this figure is to establish trends rather than absolute values. The figure illustrates that for the higher supply heads the dimensionless ram performances tend to be similar. (Some divergence is observed for the lower supply head, partly owing to the length of drive pipe used in the test installation (approx. 12 m), which is somewhat on the large side for a supply head $H_s = 1.35$ m.)

It must be noted that the foregoing performance characteristics have been obtained from experiments taken on two commercial hydraulic rams and in a way are restricted to these specific rams. However, general conclusions on ram performance as portrayed in the figures may be found to be true for any well-designed ram, but the exact shape of the curves and the magnitude of the numerical values will vary according to the particular design. Detailed information on performance characteristics of twelve commercial rams are included in lit. [4].

Summary and conclusions

In this article it is sought to clarify hydraulic ram operation, using a limited number of results obtained from a more comprehensive analysis (lit. [4]).

The hydraulic ram owes its pumping capacity to two facts. For one thing the action of two (simply constructed) valves, for another the high value of the wavespeed (c) at which pressure waves propagate through a liquid in a pipeline. The latter implies that the drive pipe of the hydraulic ram installation must be made of strong, rigid material (small

elasticity), and that the water in the drive pipe must be free of air (small compressibility).

Starting from the motion of the two valves, the pumping cycle of a hydraulic ram can be divided into three (sub-)periods: acceleration - retardation - recoil. For each period the velocity of the water at the downstream end of the drive pipe as a function of time is briefly discussed. With the aid of high-frequency pressure recordings, special attention is paid to the period of retardation; it is in this part of the pumping cycle that the actual pumping takes place.

More information concerning a mathematical model and results of laboratory tests are available (lit. [4]), but there is a lack of results from field tests.

Conclusions relating to the performance characteristics of the hydraulic ram are:

- given an available source supply the pumping rate (q) is primarily determined by the supply head (H_s) and the delivery head (h_d).
- an increase of the delivery head (h_d) decreases the quantity pumped per cycle (V_p) and by that the pumping rate (q) decreases.
- an increase of the supply head (H_s) increases the pumping frequency and by that the pumping rate (q) increases.
- the larger the size (i.e. drive pipe bore) of the ram, the more water (Q) is required to operate the ram and the more water (q) can be delivered to a higher level (h_d).

These conclusions were found to be in conformity with the fore-mentioned mathematical model as well as with experimental results. They can also be drawn from the few results in this article concerning one specific type of hydraulic ram.

References


- [1] Lansford, W.M., Dugan, W.D.
'An Analytical and Experimental Study of the Hydraulic Ram', University of Illinois Engineering Experiment Station, Bulletin Series No. 326, Urbana, Illinois, 1941.
- [2] Renaud, H.
'Le Bâlier Hydraulique', Dunod, Paris, 1950.
- [3] Schiller, E.J. (ed.)
'Proceedings of a Workshop on Hydraulic Ram Pump (Hydram) Technology - held at Arusha, Tanzania, 1984', International Development Research Centre - Manuscript Report (IDRC-MR 102e), Ottawa, Canada, 1985.
- [4] Tacke, J.H.P.M.
'Hydraulic rams - a comparative investigation', Communications on hydraulic and geotechnical engineering - Report no. 88-1, Delft University of Technology, Department of Civil Engineering, Delft, 1988.
- [5] Jong, P. de
'Hydraulic rams - consumers guide', CICAT, Delft University of Technology, Delft, 1988.

For further information please contact:
Laboratory of Fluid Mechanics, Department of Civil Engineering, Delft University of Technology, P.O. Box 5048, 2600 GA Delft, the Netherlands.

HYDRAULIC RAMS

Consumers guide

P. de Jong




 **TU Delft**

Delft University of Technology

centre for international cooperation
and appropriate technology

consumers guide

HYDRAULIC RAMS



p. de jong

delft university of technology

centre for international cooperation
and appropriate technology

	page	
1. Introduction	..	2
2. Appropriate water supply	..	2
3. Hydraulic rams	..	3
4. Description of hydraulic rams	..	3
5. Basic Requirements	..	4
6. Site selection	..	5
7. Installation and maintenance	..	7
8. Prices and costs	..	8
Appendices:		
a. Operation of hydraulic rams and characteristics	..	9
b. Results of the comparative laboratory and field tests	..	13
c. Calculation example	..	16
d. Bibliography	..	17
e. Adresses of hydraulic ram manufacturers	..	19

1. Introduction

This report is the result of a project, called "comparative tests on commercial and newly designed waterrams", carried out by the Delft University of Technology and the Foundation of Dutch Volunteers in Rwanda.

The aim of this project was twofold:

- to test new, and cheap (i.e. locally constructable and maintainable) types of hydraulic rams,
- to compare several commercial types, in order to make a "consumers guide" for developing countries.

At the Laboratory of Fluid Mechanics of the Delft University of Technology the most essential aspects of the behaviour of commercially available rams were compared. Valve behaviour, delivery head, delivered quantity and efficiency were accentuated.

Samples of the rams, tested in the laboratory were checked in Rwanda on reliability, durability and possibilities for local maintenance.

2. Appropriate water supply

A reliable water supply is one of the basic needs of people. It is a rather disappointing experience to find a dried-up well after several miles of walking, or to get just a few drips of brown water out of an expensive pump. Many people are dealing with this sort of problems, especially in the arid areas of the Third World.

A lot of pumping systems were developed to fulfill this need:

- # hand-driven pumps, using human energy to get water out of the earth or river into a bucket or to lift water to a certain level (into a storage tank) from which it can be distributed.
- # an improvement is found in using animal traction instead of human energy. Transmission is necessary, but outputs are five to ten times greater than that of man.
- # the next step is to use fossil fuels or renewable energy for pumping. Animals can be used for other activities, instead of pumping for many hours, the pump can be used 24 hours per day and delivery of larger quantities of water are possible.

The pump itself, of course, has to be appropriated to its use and to its energy system. A donkey will pull harder than a man, the beats of a diesel pump will effect the pump in a totally different way than the constant rounds of the cattle. The hand pump is a simple design, means less maintenance and is easy to repair. Diesel and electric pumps are more sophisticated, but they require technical know-how and installation, maintenance and repair facilities.

Another disadvantage of diesel and electric pumps, is the dependence on fuel. Disruptions in the fuel supply will stop the pump and the total water installation.

For this reason 'appropriate technologists' have been looking for renewable energy sources: solar, wind and biomass energy and hydropower. Depending on the environmental and economical situation and, again, the available facilities, a choice can be made:

- # solar energy (photovoltaic cells, control device and a electric pump) requires a high level of technical skills and investment. The systems

can only be imported from industrialized countries.

- # wind energy (rotor, power transmission mechanism and a pump or a wind-driven electro-generator and an electric pump) requires also an investment higher than for diesel pumps, but has lower running costs and it can have a longer service life. A suitable wind regime is necessary; the average wind speed has to be higher than 3.5 m/s.
- # biomass can be processed to combustible gasses or liquids, which can be used as fuel for small engines to drive water pumps. Special energy crop production will be necessary most of the time; a trained operator is essential. Due to the minimum size of a biomass plant, such systems will not be adequate under quantities of 150 m³ of delivered water daily.
- # hydro-powered pumping systems, which could be divided into three main types:
 - turbine pumps, a water turbine with a centrifugal pump (flow of river, stream or channel 15 m/s, drive head of at least 0.5 m).
 - river current pumps, a vertical shaft rotor with transmission to a small centrifugal pump on a floating pontoon (e.g. flow of river 1.0 - 1.5 m/s, delivered quantity 100 - 300 l/min to a delivery head of 5 m).
 - hydraulic rams, a good solution if the conditions are favourable.

A more complete overview of the possibilities is given in 'Renewable Energy Sources for Rural Water Supply' (litt. 9).

3. Hydraulic rams

The decision to choose rams could be made after surveying the situation, measuring the available source supply, the obtainable supply head and the required delivery head as well as some additional data.

If the basic requirements could be fulfilled and the possible site meets its criteria (§ 5 and § 6), rams can be considered.

A final aspect of such a decision is the price of the system (§ 8).

In appendix A the operation of the ram is described including some specifications of the normally used characteristics. Furthermore, a comparison of rams in the laboratory and in the field, as well as a calculation example and addresses of manufacturers are given in the appendices.

4. Description of hydraulic rams

The various components from which a typical hydraulic ram installation is constructed are supply reservoir, drive pipe, hydraulic ram, delivery pipe and a storage tank.

The hydraulic ram itself is structurally simple, consisting of a pump chamber fitted with only two moving parts: an impulse valve through which the driving water is wasted (waste valve) and a delivery valve (check valve) through which the pumped water is delivered.




Fig. 1. Nomenclature of a hydraulic ram

In empty condition the waste valve normally falls open by gravity. Some designs of hydraulic ram use spring-activated waste valves. The delivery valve usually is a simple rubber disc covering a ring of holes. Surmounting the delivery valve is the air chamber or surge tank. When the ram operates, this tank is partly filled with water and partly with air. Connected to the air chamber is the delivery pipe, so the pressure in the air chamber is the delivery pressure. An inclined conduit, the so-called drive pipe, connects the ram body with the water supply. This drive pipe is the essential part of the installation in which the potential energy of the supply water is first converted into kinetic energy and subsequently into the potential energy of water delivered.

5. Basic Requirements

The use of a hydraulic ram requires the availability of suitable and reliable supply of water, with a sufficient fall to operate the ram. The supply can be any source of flowing or stagnant water such as a spring, stream, river, lake, dam or even a pond fed by an artesian well. Small size rams require a supply flow of at least 5 to 25 litres per minute, whereas very large rams may need as much as 750 to 1500 l/min. For most hydraulic rams the fall in driving water from the source to the ram must be at least 1 m.

Of course, not every spring, river etc. is suitable. The quality of the water is very important and has to be checked first. Most countries and communities have their own quality standards and methods of control. If the quality is not sufficient, complementary measurements have to be taken.

6. Site selection

When selecting a potential site for the hydraulic ram installation it is essential that provisions can be made both for water input to the ram and for proper drainage of the waste water away from the ram. The waste valve should under no circumstances, flood conditions included,

be submerged, since this will seriously affect its operation.

Before any possible lay-out of the installation can be designed, information must be gathered on the following items:

- 1) Amount of water available to power the ram (source flow) [l/min]
- 2) Minimum quantity of water to be pumped (delivery flow) [l/day]
- 3) Working fall (supply head) which can be obtained [m]
- 4) Distance in which the working fall can be obtained [m]
- 5) Vertical lift from ram site to delivery site [m]
- 6) Length of delivery pipe from ram to delivery site [m]




Fig. 2 Site of a hydraulic ram. $h_d = a + b$ (cross section and top view)

Unless the supply water is obviously more than adequate, the source flow must be measured with reasonable accuracy. The possible change of flow at different times of the year should be established in order to determine the minimum guaranteed flow available.

The total daily volume of water required to be pumped can be calculated according to the purpose of use. For example, if the water is to be used for domestic consumption, the daily demand may be approximated by:

$$\text{Water Demand} = \text{Users} * \text{Per Capita Consumption}$$

A typical per capita consumption could be 40 to 50 litres/person/day. If

live- stock is present, its water use should be included also. Given the fact that the hydraulic ram is capable of operating continuously twenty-four hours per day, the required pumping rate (q) is obtained by dividing the daily water demand by $24 \cdot 60 = 1440$ minutes; in formula:

$$\text{Pumping Rate } q \text{ [l/min]} = \frac{\text{Water Demand [l/day]}}{1440 \text{ [min/day]}}$$

The working fall (supply head H_s) is measured vertically from the supply source level to the output level at the waste valve of the ram. The pumping capacity varies directly with the supply head.

The supply head can be increased by increasing the input level (e.g. by selecting the water input further upstream) and/or by lowering the position of the ram itself (as long as it can be placed on a spot from which the waste water can be easily drained away, e.g. to a suitable discharge point further downstream).

The next question to be answered is what pressure head the hydraulic ram will need in order to lift the water to the storage tank and to overcome all energy losses. In general this will be equal to:

$$\text{Delivery Head } (h_d) = \text{Vertical Lift above Ram} + \left[\frac{f L_d}{d} + \xi_d \right] \frac{v^2}{2g}$$

where

f	= pipe friction factor	[-]	(0.02 - 0.04)
L_d	= length of delivery pipe	[m]	(50 - 2000)
d	= internal diameter of delivery pipe	[m]	(0.02 - 0.05)
ξ_d	= sum of minor loss factors	[-]	(0 - 10)
v	= average velocity in delivery pipe	[ms ⁻¹]	(0.2 - 0.5)
g	= acceleration due to gravity	[ms ⁻²]	(9.8)

Vertical lift must be measured from the location of the ram to the highest possible water surface level (overflow level) in the storage tank. Minor losses may usually be neglected (or roughly estimated) as compared with vertical lift and friction head loss.

Knowing the available source supply (Q_{source}), the required pumping rate (q), the supply head (H_s) and the delivery head (h_d) the size of the hydraulic ram can be selected with the aid of the appropriate performance tables or, when available, with use of empirically obtained q/Q vs h_d/H_s curves:

The sum of the waste flow (Q) used by the ram and the pumping rate (q) must be less than the minimum source flow, i.e. $Q + q < Q_{\text{source}}$

Since supply head (H_s) and delivery head (h_d) are more or less fixed by the terrain conditions (topography), the size of the hydraulic ram is mainly determined by the desired pumping rate, or limited by the available source supply to drive the ram.

In cases where the installation has not enough capacity to meet the daily water demand, a battery of several rams may be used. Of course, this requires a source which can supply water at a sufficient rate. Each ram must have its own individual drive pipe, but they may use the same delivery pipe unless they are meant to supply different places.

A battery of hydraulic rams is also very useful in situations where the minimum flow during periods of drought only can power one or two rams and the maximum flow can drive more rams.




Fig. 3. Battery of a hydraulic rams

In a case where the supply water can power only one hydraulic ram, but the delivery flow does not quite meet the water demand, the waste water from the initial ram could be used to drive another ram.

7. Installation and maintenance

Since the hydraulic ram undergoes savage pounding under operation, it should be firmly bolted to a concrete base.

The drive pipe is by far the most important part of the installation; it carries the water from the supply reservoir to the ram and contains the high pressure surges (waterhammer) during the pumping stage of the operating cycle of the ram. The drive pipe should therefore be made of strong, rigid material, preferably galvanized iron. It should be watertight and rigidly anchored. The length should be approximately 4 to 7 times the supply head H_s .

The inlet to the drive pipe must always be submerged to prevent air from entering the pipe; air bubbles in the drive pipe will dramatically affect the operation of the ram or even lead to complete failure. For this reason the drive pipe should be laid as straight as possible throughout its entire length without any elevated sections which could trap air. A dip to allow the drive pipe to follow the contour of the ground is permissible.

The delivery pipe may be made of any material (e.g. P.V.C. - polyvinyl chloride or HDPE - high density polyethylene) provided it can withstand the delivery pressure.

If the delivery head exceeds the pipe's pressure specification, then the lower portion of the delivery pipe must be galvanized iron pipe. In fact it may be advisable always to use an initial length of galvanized iron pipe to ensure a sturdy connection to the ram.

To facilitate operation and maintenance of the hydraulic ram the drive pipe and the delivery pipe should each be connected to the ram with union joints and stop-valves. The stop-valve in the drive pipe should be incorporated in such a manner as to prevent the formation of air pockets; a rotary type of valve (globe valve) is preferable to an ordinary gate valve since the latter may not be strong enough against the severe loads of the waterhammer pressures.

The maintenance required for a hydraulic ram is, compared to most other pumping systems, very little and infrequent. It includes:

- replacement of the valve rubbers when they are worked out
- adjustment of the tuning of the waste valve
- tightening bolts which have worked loose.

Occasionally the hydraulic ram may need dismantling for cleaning. It is essential that as little debris as possible enters the drive pipe. It is therefore necessary to provide a grate at the intake of the supply source as well as a strainer at the inlet side of the drive pipe to hold up floating leaves and debris. The grate and strainer must be checked every now and then and cleaned if necessary to ensure that the water supply is flowing at the maximum rate.

It must be stated that the foregoing remarks on the practical use of the hydraulic ram only highlights some of the main features of the installation. Every situation may vary in detail; specific design and techniques suited to the particular site may be necessary to create the most appropriate hydraulic ram installation.

More detailed information on how to construct, operate and maintain the ram installation is depending on the type of ram and can be found in the appropriate product information. Some manufacturers (e.g. Blake, Jandu, Schlumpf and Vulcan) do supply comprehensive information.

8. Prices and costs

Prices of hydraulic rams vary from US \$ 1000 to US \$ 3500. During the research in Rwanda it became clear that this price is a small part of the total costs of a complete water supply system. A rough breakdown of these costs looks as follows

pipes and accessories	45 %
construction works	30 %
transportation (including transport from Europe to Africa)	15 %
hydraulic rams	10 %

Although rams do not have fuel costs, expenses for spare parts and maintenance are most common. There has to be someone available for regular check-ups and reparations (weekly to monthly). This person should be trained first.


The percentual breakdown of the total costs leads to the conclusion that the price of the ram itself is of less importance. A cheap ram with a low output and a bad performance could throw the whole expensive system idle.

The risk of drop out of the total system is also rather high when other parts of the system, e.g. the drive pipe, were not installed very solidly.

Another lesson which could be learned from the total costs overview is the knowledge on the availability of all materials is essential in order to make a realistic estimation of the total costs.

A.1. Operation of hydraulic rams

The ram operates on a flow of water falling under a head (abbreviated H_s) from the supply reservoir down through the drive pipe into the pump chamber. The water escapes through the opened waste valve into the surrounding area. With the acceleration of the water the hydrodynamic drag and pressure on the waste valve will increase. When the flow of water through the waste valve attains sufficient velocity, the upward force on the valve will exceed its weight and the valve will slam shut. (In a good ram design the valve closure is rapid, almost instantaneous.)





Thus the flow through the waste valve is abruptly stopped, but since the column of water in the drive pipe still has a considerable velocity a high pressure develops in the ram, locally retarding the flow of water.

If the pressure rise is large enough to overcome the pressure in the air chamber the delivery valve will be forced open, which in turn limits the pressure rise in the ram body to slightly above the delivery pressure. The front of this pressure rise expands upstream, partly reducing the flow velocity in successive cross-sections of the drive pipe as it passes. In the meantime the remainder of the flow passes through the opened delivery valve into the air chamber. The 'air cushion' permits water to be stored temporarily in the air chamber with only a comparatively low rise in local pressure, thus preventing the occurrence of waterhammer (shock waves) in the delivery pipe.

With the propagation of successive pressure surges up and down the drive pipe water continues to flow into the air chamber with step-wise decreasing velocity until the momentum of the water column in the drive pipe is exhausted.

The higher pressure which now exists in the air chamber will initiate a reversal flow in the direction of the supply reservoir. This causes the delivery valve to close, preventing the pumped water from flowing back into the ram body. The 'recoil' of water in the drive pipe produces a slight suction in the ram body, thus creating an underpressure near the waste valve. The underpressure makes it possible for the waste valve to reopen, water begins to flow out again, and a new operating cycle is started.



Meanwhile the water forced into the air chamber, is driven into the delivery pipe to the storage tank at the high level, from which it can be distributed by gravitation as required.

An air valve or snifter valve is mounted into the ram body to allow a small amount of air to be sucked in during the suction part of the ram cycle. This air is carried along with the next surge of water into the air chamber. The air in this chamber is always compressed and needs to be constantly replaced as it becomes mixed with the water and lost to the storage tank. Without a suitable air valve the air chamber would soon be full of water and the hydraulic ram would then cease to function.

Depending on supply head, waste valve adjustment and, to a lesser degree, on drive pipe length and delivery head the cycle is repeated with a frequency of about 30 to 150 times a minute.

Once the adjustment of the waste valve has been set (valve stroke and - if present - tension of the return spring), the hydraulic ram needs almost no attention provided the water flow from the supply source is continuous, at an adequate rate and no foreign matters get into the pump blocking the valves.

A.2. Characteristics

For users of the ram the pumping rate q (output capacity) is the first consideration, since this should meet their demand.

Given an available source supply the pumping rate q of a hydraulic ram is determined by the supply head H_s and the delivery head h_d .

An increase of supply head H_s increases the pumping frequency (more beats per minute) and thereby increases the pumping rate q .

Commercially-made hydraulic rams are available in various sizes, covering a wide range of source supplies. The size of the ram (traditionally given in inches) usually denotes the nominal diameter of the drive pipe. The larger the size of the ram the more water is required to operate the ram and the more water can be delivered to a higher level.

Efficiency requires some special attention since different expressions are obtained in product information as well as in literature.

Some give the Rankine equation considering the installation as a whole and taking the head water level as datum. The useful work done in unit time, i.e. the net amount of potential energy of the water delivered, is given by $\rho g q (h_d - H_s)$. The net amount of energy used by the ram, i.e. the change in potential energy of the driving water is given by $\rho g Q H_s$.

$$\eta_{\text{rnk}} = \frac{\Delta E_{\text{pot}} \text{ water delivered}}{\Delta E_{\text{pot}} \text{ driving water}} = \frac{q \cdot (h_d - H_s)}{Q \cdot H_s}$$

In product information of hydraulic ram manufacturers, as well as in some other publications, efficiency is often simply defined as

$$\eta_{\text{trd}} = \frac{q \cdot h_d}{Q \cdot H_s}$$

The Rankine figure is always the lowest, while the 'trade expression' yields somewhat higher values; especially at low delivery heads the difference is significant.

The efficiency curve is most important when the supply source is limited and waste water must be kept at a minimum. In situations where there is an abundance of supply water the efficiency is a secondary matter. However, efficiency figures give a good indication of the hydraulic performance of the ram. High efficiency machines are hydraulically well-designed, i.e. have fair and smooth waterways and consequently low energy losses.

It should be standard commercial practice that manufacturers of hydraulic rams provide comprehensive and reliable information on the performance characteristics of their rams. Unfortunately this is not always the case.

For example, some ram manufacturers state that the 'output' of their rams can be calculated using the simple formula

$$q = \frac{Q \cdot H_s}{h_d} \cdot 0.6$$

The formula is based merely on the rule of thumb which means that the efficiency of a hydraulic ram is around 60 %. Apart from the fact whether the specific ram is capable of attaining this efficiency, it is unlikely that the use of the formula is correct for all arrangements of supply and delivery heads, since it has been found from experiments that efficiency eventually diminishes as head ratio h_d/H_s increases.

A more realistic approach is followed by manufacturers recommending the formula

$$q = \frac{Q \cdot H_s}{h_d} \cdot \eta$$

where numerical values of η are given in relation to head ratio h_d/H_s .

Only a few manufacturers provide empirically obtained operating tables.

B. Results of the comparative laboratory and field tests

In the Laboratory at Delft 12 types of hydraulic rams of 6 manufacturers were tested. An important result of this investigation was a sound theoretical description of what is happening inside the ram (litt. #1). This was the basis of this guide and will be a valuable point of departure for further research.

The results are given in the table on the next two pages. Specific remarks and assessments (field tests) are given at the end of this appendix. Figures for efficiency and pumping capacity, are placed next to the price per type.

In the field tests in Rwanda it became clear that hydraulic rams are sensitive to damage and obstruction, and depend strongly on the functioning of the rest of the system (drive and delivery pipe). Maintenance and repair played an important role.

It has to be kept in mind that the rather negative picture has been caused by the field testing procedure. While testing, the output should be watched continuously. In Rwanda however, weekly to monthly checks were carried out and there was not enough time to solve occurring problems immediately. A delay of some weeks in maintenance or repair of a ram is not a characteristic of that particular ram.

Another disadvantage of the procedure followed during the field tests as well as in the laboratory is the use of just one prototype of every model. Yet it is possible that just a good or worse prototype is used. There seems to be no direct relation between price and efficiency as can be seen in the table on the following pages. Keeping in mind the earlier statements on the total costs of a water supply system and the importance of efficiency, hydraulic rams with an efficiency less than about 55 % are disproportionately expensive.

The schedule on the testing program prevented the investigation of the newly designed rams Mbaraga I and II. These rams were designed after the unsatisfactory experiences (maintenance) in the field test after finishing the laboratory tests.

The locally designed and constructed hydraulic rams (Mbaraga I and II, as well as the HDG ram) are, compared to the commercially available rams, still in a too experimental stage to judge their value. Justification for the use of this types could be caused by the specific local situation (availability of other rams and materials, transport problems, construction capacity etc.).

Hydraulic ram	Supply Head Hs	Waste Flow Q (a)	Period Time T (a)	Delivery Head hd [m]	
	[m]	[l/min]	[s]	from	to
Blake Hydram No. 2 (1.5")	1.35	40	1.600	12	112
	2.00	39	1.000	11	130
	3.00	38	0.700	11	140
Blake Hydram No. 3,5 (2.5")	1.35	110	1.600	8	112
	2.00	100	1.000	8	120
	3.00	95	0.700	12	133
Alto J 26-80-8 (1")	1.00	14	1.300	6	19
	2.00	14	0.700	9	33
	3.00	15	0.550	12	42
Alto CH 50-110-18 (2")	1.00	33	1.000	6	40
	2.00	36	0.600	7	60
	3.00	39	0.450	10	66
Vulcan 1" (1")	1.00	15	1.550	4	75
	2.00	17	0.950	8	117
	3.00	16	0.650	13	134
Vulcan 2" (2")	1.00	35	1.150	6	68
	2.00	33	0.600	12	80
	3.00	34	0.450	18	88
SANO No 1-25 mm (1")	1.00	10	1.100	4	67
	2.00	10	0.550	9	81
	3.00	10	0.400	11	93
SANO No.4-50 mm (2")	1.00	60	1.900	4	102
	2.00	55	0.900	8	120
	3.00	60	0.650	12	138
Davey No. 3 (1")	1.00	13	1.900	2	28
	2.00	13	1.000	4	44
	3.00	12	0.750	6	54
Rife 20 HDU (2")	1.25	85	2.500	4	112
	2.00	80	1.300	4	133
	3.00	80	0.900	6	154
Schlumpf 4A5 (1.5")	1.00	25	1.500	4	32
	2.00	32	1.400	6	29
	3.00	30	1.000	9	27
Schlumpf 4A23 (1.5")	1.00	25	1.900	4	40
	2.00	45	1.600	8	78
	3.00	36	1.100	9	73

(a) approx. average value for the whole range of operation

Hydraulic ram	Pumping Rate q [l/min]		Efficiency	Price	Maintenance
	from	to	% (b)	(c)	Durability Reliability (d)
Blake Hydram No. 2 (1.5")	2.00	0	44/42/37	£ 250	
	4.75	0	62/64/60		
	7.70	0	67/70/67		
Blake Hydram No. 3.5 (2.5")	9.95	0	51/51/45	£ 450	-
	17.15	0	65/64/57		-
	20.30	0	70/73/68		+
Alto J 26-80-8 (1")	1.10	0	- / - / -	Frs 3550	
	1.75	0	45/ 8/ -		
	2.20	0	38/ - / -		
Alto CH 50-110-18 (2")	1.25	0	37/ - / -	Frs 6950	-
	3.05	0	40/36/ 1		+
	4.45	0	38/41/22		++
Vulcan 1" (1")	1.00	0	36/34/18	£ 165	
	1.00	0	48/52/51		
	2.25	0	52/58/57		
Vulcan 2" (2")	4.25	0	70/63/31	£ 365	
	5.05	0	75/68/54		
	5.40	0	76/71/56		
SANO No.1-25 mm (1")	1.05	0	45/35/11	DM 700	
	1.50	0	60/59/44		
	2.05	0	61/64/54		
SANO No.4-50 mm (2")	4.70	0	38/32/27	DM 1350	-
	8.40	0	63/63/62		-
	10.25	0	65/68/66		-
Davey No. 3 (1")	2.67	0	26/ - / -	£ 250	
	3.77	0	51/16/ -		
	4.80	0	59/47/ -		
Rife 20 HDU (2")	3.90	0	26/28/27	\$ 800	-
	8.90	0	42/54/45		-
	12.90	0	45/47/48		-
Schlumpf 4A5 (1.5")	3.85	0	- / - / -	SFr 2000	
	9.30	0	22/ - / -		
	10.30	0	38/ - / -		
Schlumpf 4A23 (1.5")	3.70	0	37/ 2/ -	SFr 3000	-
	7.65	0	44/33/ 8		-
	11.70	0	53/35/16		-

(b) for resp. h = 20 m, 40 m and 60 m
(c) global prices 1980/1981

(d) according to field tests

Remarks and assessments per ram (field tests)

Blake 3 1/2"

During the 1 1/2- year testing-period of this ram it has been standing still during most of the time due to external influences (drive and delivery pipes and a flexible joint). The joint between drive pipe and ram body seemed to cause heavy trouble for local maintenance.

SANO 4

With the Sano-ram also external influences played an important role. The delivery valve caused trouble time and again.

Schlumpf No. 4A23

Again external factors were of great influence. After a few days the delivery valve had to be modified fundamentally.

Vulcan 2 1/2"

After some starting problems this ram worked reasonably although a lot of time was lost due to external factors. Repairing was necessary twice; a new gasket and two rubber delivery valve clacks.

Vulcan 2"

Misjudgement during the installation (wrong interpretation of the pump behaviour due to a leaking drive pipe) of this Vulcan caused its premature removal. So classification is not possible.

Rife # 20 HDU

The Rife could not function under the given conditions, although according to the description of the manufacturer, it should have been possible.

Alto CH No. 50-110-18

With the Alto the installation problems already appearing by the Vulcan 2", showed up again. After repairing the drive pipe and slowing down the waste valve by some modifications, there were no internal break-downs, but the drive pipe broke again, combined with a period with lack of water. After a working period of 16 months the Alto ram was extremely worn down, also as a result of aggressive water.

Mbaraga I & II

Mbaraga I & II are designed locally and constructed hydraulic rams. This was done because of the poor results of the commercially available rams. These rams were not tested in Delft but nevertheless a, not surprising, result can be given: reliability and durability were very poor and access of local maintenance was good

C. Calculation example

Given: a community of 60 persons and some cattle (30)

$$\text{Water Demand} = \text{Population} \cdot \text{Capita Consumption}$$

The capita consumption depends on geographic, social and cultural aspects, but most of all on the availability of water. The domestic consumption could be 2 - 5 liters daily, with a population living 15 km from a water source. Having a watertap, shower and adjusted toilet, it could be 60 - 80 litres per day per person.

For this example is calculated with 50 litres daily and 20 litres for the local cattle per animal. So,

$$\text{Water Demand} = 60 \cdot 50 + 30 \cdot 20 = 3600 \text{ l/day}$$

The pumping rate (continuously pumping) will be

$$\text{Pumping Rate} = \frac{3600}{1440} = 2.5 \text{ l/min}$$

The next figure needed is the delivery head. Herefore is given:

$$f = 0.04 \text{ (estimation, depending on the pipes available)}$$

$$Ld = 1000 \text{ m (to be measured in the field)}$$

$$d = 0.02 \text{ m (a suitable diameter for this pumping rate ? Has to be checked.)}$$

$$\xi d = 10 \text{ (estimation for a long and difficult track)}$$

$$v = 0.3 \text{ ms}^{-1} \text{ (estimation, has to be checked)}$$

$$g = 9.8 \text{ ms}^{-2}$$

$$\text{Vertical lift} = 40 \text{ m (to be measured in the field)}$$

$$h_d = 40 + \left[\frac{0.04 \cdot 1000}{0.02} + 10 \right] \frac{0.3^2}{2 \cdot 9.8} = 49 \text{ m}$$

As shown in the table on page 13 and 14 such a supply could be created with e.g. a Blake Hydram no. 2 or some others, using a supply head of 3.00 m at least and a supply flow around 60 l/min. With a given efficiency of 70 % this will result in

$$q = \frac{60 \cdot 3.00}{49} \cdot 0.70 = 2.57 \text{ l/min}$$

D. Bibliography

- # 1 Hydraulic rams, a comparative investigation, 112 pp. + 143 pp. appendices, 1987
J.H.P.M. Tacke, Laboratory of Fluid Mechanics, DUT
Centre for International Cooperation and Appropriate Technology,
Delft University of Technology, P.O. Box 2600 GA Delft, The
Netherlands
- # 2 A manual on the hydraulic ram for pumping water, 40 pp., 1978
S.B. Watt
Intermediate Technology Development Group, 9 King Street,
London WC2E 8HW, United Kingdom
- # 3 De waterram - een theoretische beschouwing n.a.v. een a.t.
ontwerp, 70 pp., (Nederlands), 1976
K. Kempenaar and H. Wesseling, DUT
Centre for International Cooperation and Appropriate Technology
- # 4 Field tests on hydraulic rams in Rwanda, 1987
E. Hamel, SNV
Foundation of Dutch Volunteers, Bezuidenhoutseweg 161, 2594
AG, The Hague, The Netherlands
- # 5 Drawings of hydraulic rams, 42 pp., (Duits/Engels), 1979
German Appropriate Technology Exchange, Postfach 5180,
D-6236 Eschborn, Germany
- # 6 Proceedings of a workshop on hydraulic ram pump (hydram)
technology, Arusha, Tanzania, 121 pp., 1984
E.J. Schiller, ITDG
Intermediate Technology Development Group
- # 7 The construction of a hydraulic ram pump, 36 pp.
A.R. Inversin
South Pacific Appropriate Technology Foundation, P.O. Box 6937,
Boroko, Papua New Guinea
- # 8 Ontwerp en bouw van een waterram proefinstallatie, ontwikkeling
waterramimpulsklep simulatiemodel, 51 pp. + bijlagen,
(Dutch), 1986
H.M. Zilvold, HTS Zwolle, The Netherlands
- # 9 Renewable Energy Sources for Rural Water Supply, 133 pp. +
appendixes, 1986
International Reference Centre, P.O. Box 93190, 2509 AD, The
Hague, The Netherlands
- # 10 A handbook of gravity-flow water systems, 186 pp. + appendixes,
1980
Intermediate Technology Development Group

E. Adressses of hydraulic ram manufacturers

Alta Cabeza "Gaviotas"	Centro Las Gaviotas, Paseo Bolivar no. 20 - 90, Bogota, Columbia
Auto-Lift Pump	Godbole & Sons, New Ramdaspath, Kachipura, Nagpur - 1, India
Bélier ALTO	J.M. Desclaud, 57, Rue Bertrand-de-Goth, 33800 Bordeaux, France
Billabong	John Danks & Son, Pty Ltd, Doody Street, Alexandria, Sydney, New South Wales, Australia
Blake Hydram	John Blake Ltd, P.O. Box 43, Accrington, Lancashire BB5 5LP, UK
Bomba Hidraulicas Rochfer	Industrias Mecanicas Rochfer Ltda, Avenida Jose de Silva 3765, Jardim Moria Rosa, Caixa Postal 194, Sao Paulo, CEP 14400, Brazil
Briau Hydram	Briau S.A., B.P. 43, 37009 Tours, France
BZH Hydrauliska	Ab Bruzaholms Bruk, 570 34 Bruzaholm, Sweden
CeCoCo Hydro-Hi-Lift Pump	CeCoCo, P.O. Box 8, Ibaraka City, Osaka 567, Japan
Chandra Hydram	Singh Metal Casting Works, 110-D Nirala Nagar, Lucknow, India
Fleming Pump	C.W. Pipe Inc., P.O. Box 678, Amherst, Virginia 24521, USA
Jandu's Hydram	Jandu Plumbers Ltd, P.O. Box 409, Uhuru Road, Arusha, Tanzania
Pompe Pilter	Pilter, 22, Rue Florian, 75020 Paris, France
Premier Hydram	Premier Irrigation Equipment Ltd, 17/1C Alipore Road, Calcutta 700.027, India
Rife Ram Pump	Rife Hydraulic Engine Manufacturing Co., 316 W. Poplar Street, P.O. Box 790, Norristown, PA 19401, USA
SANO Ram Pump	Pfister & Langhanss, Sandstraße 2-8, Postfach 3555, 8500 Nürnberg 1, Federal Republic of Germany

Schlumpf Pump

Schlumpf AG, CH-6312 Steinhausen,
Kanton Zug, Switzerland

Vulcan Hydram

Green & Carter Ltd, Ashbrittle, Near
Wellington, Somerset, TA21 0LQ UK

Wama Pump

WAMA Maschinenbau, Bergstraße 8,
8018 Grafing bei München, Federal
Republic of Germany